



Wells Recirculation Ventless Hoods – Getting Started

Before you order a new Wells Ventless System please review the following suggestions to ensure a trouble-free experience.

1. Choose the model(s) that best suits your needs: (over 30 models to choose from).
2. Read the spec sheet and owner's manual before ordering. Available at www.wellsbloomfield.com
3. Dimensions & Measurements: verify the appliances will fit, that there is adequate vertical clearance and that the hood can be maneuvered into the space. Measure twice, order once.
4. Ask Wells to check your equipment schedule to verify everything fits and is UL compliant.
5. Pull permits: Fire system, electrical and mechanical permits may be required in your area.
6. HVAC: A well ventilated space is needed. We recommend you have an engineer or mechanical contractor review your plans and existing HVAC system.
7. Electrical: Verify that sufficient electrical service is available to power the cooking equipment. Note that the control panels on some models require an interconnection with the cooking appliances.
8. Fire Protection: speak with a local licensed ANSUL agent before ordering. Does the building have a fire alarm panel? Is a remote pull required at way of egress? Charging and tagging the ANSUL system must be performed by a licensed ANSUL agent and is not Wells responsibility.
9. Wells Ventless systems are made-to-order and are non-returnable, so do your homework.
10. Place your order.