



SMALL APPLIANCE VENTLESS HOODS (SA VENTS)
PRE-PIPED FOR ANSUL R-102 FIRE SYSTEM

UL 300


COMPLIANT

**All pre-piping
work
performed by
licensed Ansul
distributor**



INCLUDES (installed)

- Nozzle(s)
- Swivel(s)
- Nozzle caps
- Chrome dipped
Piping and fittings
- Fusible link
detector bracket
with internal
conduit



EXCLUDES:

- | | | |
|--|--------------------------------------|---|
| - Automan Control Assembly | - Fusible link and cable | - Electrical wiring |
| - 1.5 Gallon Tank Assembly | - Interconnecting piping and conduit | - Permits and fees |
| - Shunt trip breakers to turn off
SA Vent and appliance | - Remote pull station and cable | - Field inspections and
testing for local
authorities |
| | - Pulleys | |
| | - Charged cartridge | |